

1
2

Table 5-2. Category 2 Issues Applicable to Postulated Accidents during the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
POSTULATED ACCIDENTS			
Severe accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

3 The NRC staff has not identified any new and significant information with regard to the
 4 consequences from severe accidents during its independent review of the IP2 and IP3 ER
 5 (Entergy 2007a), the site visit, the scoping process, or evaluation of other available information.
 6 Therefore, the NRC staff concludes that there are no impacts of severe accidents beyond those
 7 discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), the NRC staff
 8 has reviewed severe accident mitigation alternatives (SAMAs) for IP2 and IP3. The results of its
 9 review are discussed in Section 5.2 of this draft SEIS.

10 **5.2 Severe Accident Mitigation Alternatives**

11 As required by 10 CFR 51.53(c)(3)(ii)(L), license renewal applicants must consider alternatives
 12 to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant’s
 13 plant in an environmental impact statement (EIS), or related supplement, or in an environmental
 14 assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware,
 15 procedures, and training) with the potential for improving severe accident safety performance
 16 are identified and evaluated. SAMAs have not been previously considered for IP2 and IP3;
 17 therefore, the remainder of Chapter 5 addresses those alternatives.

18 **5.2.1 Introduction**

19 This section presents a summary of the SAMA evaluation for IP2 and IP3, conducted by
 20 Entergy, and the NRC staff's review of that evaluation. The NRC staff performed its review with
 21 contract assistance from Information Systems Laboratories, Inc. The NRC staff’s review is
 22 available in full in Appendix G to this draft SEIS; the SAMA evaluation is available in full in
 23 Entergy’s ER.

24 The SAMA evaluation for IP2 and IP3 was conducted using a four-step approach. In the first
 25 step, Entergy quantified the level of risk associated with potential reactor accidents using the
 26 plant-specific probabilistic safety assessment (PSA) and other risk models.

27 In the second step, Entergy examined the major risk contributors and identified possible ways
 28 (i.e., SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
 29 systems, procedures, and training. Entergy initially identified 231 and 237 potential SAMAs for
 30 IP2 and IP3, respectively. For each unit, Entergy performed an initial screening in which it
 31 eliminated SAMAs that are not applicable to IP2 and IP3 because of design differences, have
 32 already been implemented at IP2 and IP3, or are similar in nature and could be combined with
 33 another SAMA candidate. This screening reduced the list of potential SAMAs to 68 for IP2 and

1 62 for IP3.

2 In the third step, Entergy estimated the benefits and the costs associated with each of the
3 remaining SAMAs. Estimates were made of how much each SAMA could reduce risk. Those
4 estimates were developed in terms of dollars in accordance with NRC guidance for performing
5 regulatory analyses (NRC 1997). The cost of implementing the proposed SAMAs also was
6 estimated.

7 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were
8 compared to determine whether the SAMA was cost beneficial, meaning the benefits of the
9 SAMA were greater than the cost (a positive cost benefit). Entergy concluded in its ER that
10 several of the SAMAs evaluated for each unit are potentially cost beneficial (Entergy 2007b).
11 However, in response to NRC staff inquiries regarding estimated benefits for certain SAMAs
12 and lower cost alternatives, several additional potentially cost-beneficial SAMAs were identified
13 (Entergy 2008a). The NRC staff identifies potentially cost-beneficial SAMAs in Section 5.2.5.

14 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging
15 during the period of extended operation; therefore, they need not be implemented as part of
16 license renewal pursuant to 10 CFR Part 54, "Requirements for Renewal of Operating Licenses
17 for Nuclear Power Plants." Entergy's SAMA analyses and the NRC's review are discussed in
18 more detail below.

19 **5.2.2 Estimate of Risk**

20 Entergy submitted an assessment of SAMAs for IP2 and IP3 as part of the ER (Entergy 2007b).
21 This assessment was based on the most recent IP2 and IP3 PSA available at that time, a
22 plant-specific offsite consequence analysis performed using the MELCOR Accident
23 Consequence Code System 2 (MACCS2) computer program, and insights from the IP2 and IP3
24 individual plant examination (Con Ed 1992; NYPA 1994) and individual plant examination of
25 external events (Con Ed 1995 and NYPA 1997).

26 The baseline core damage frequency (CDF) for the purpose of the SAMA evaluation is
27 approximately 1.79×10^{-5} per year for IP2 and 1.15×10^{-5} per year for IP3. The CDF values are
28 based on the risk assessment for internally initiated events. Entergy did not include the
29 contributions from external events within the IP2 and IP3 risk estimates; however, it did perform
30 separate assessments of the CDF from external events and did account for the potential risk
31 reduction benefits associated with external events by multiplying the estimated benefits for
32 internal events by a factor of approximately 3.8 for IP2 and 5.5 for IP3 (as discussed in
33 Appendix G, Sections G.2.2 and G.6.2). The breakdown of CDF by initiating event for IP2 and
34 IP3 is provided in Table 5-3.

Environmental Impacts of Postulated Accidents

1

Table 5-3. IP2 and IP3 Core Damage Frequency

Initiating Event	IP2		IP3	
	CDF (Per Year)	% Contribution to CDF	CDF (Per Year)	% Contribution to CDF
Loss of offsite power ¹	6.7x10 ⁻⁶	38	1.2x10 ⁻⁷	1
Internal flooding	4.7x10 ⁻⁶	26	2.2x10 ⁻⁶	20
Loss-of-coolant accident (LOCA)	1.5x10 ⁻⁶	8	2.2x10 ⁻⁶	19
Transients ¹	1.2x10 ⁻⁶	7	8.5x10 ⁻⁷	7
Anticipated transient without scram	9.9x10 ⁻⁷	6	1.5x10 ⁻⁶	13
Station blackout	8.5x10 ⁻⁷	5	7.2x10 ⁻⁷	6
Steam generator tube rupture	7.2x10 ⁻⁷	4	1.6x10 ⁻⁶	14
Loss of component cooling water	5.8x10 ⁻⁷	3	1.1x10 ⁻⁷	<1
Loss of nonessential service water interfacing systems LOCA	3.0x10 ⁻⁷	2	2.8x10 ⁻⁷	2
Reactor vessel rupture	1.5x10 ⁻⁷	<1	1.5x10 ⁻⁷	1
Loss of 125 volts direct current power	1.0x10 ⁻⁷	<1	1.0x10 ⁻⁷	<1
Total loss of service water system	5.8x10 ⁻⁸	<1	1.0x10 ⁻⁶	9
Loss of essential service water	4.4x10 ⁻⁸	<1	5.4x10 ⁻⁷	5
	1.9x10 ⁻¹⁰	<1	1.9x10 ⁻⁸	<1
Total CDF (internal events)	1.79x10⁻⁵	100	1.15x10⁻⁵	100

¹Contributions from SBO and ATWS events are noted separately and not included in the reported values for loss of offsite power or transients.

2 As shown in Table 5-3, for IP2, loss of offsite power sequences, including station blackout
3 (SBO) events, and internal flooding initiators are the dominant contributors to CDF. For IP3,
4 internal flooding initiators, loss-of-coolant accidents (LOCAs), steam generator tube rupture
5 (SGTR) events, and anticipated transient without scram (ATWS) events are the dominant
6 contributors to CDF. The differences in the CDF contributions are attributed, in large part, to
7 several significant differences between the IP2 and IP3 units.

8 Entergy estimated the dose to the population within 80 kilometers (50 miles) of the IP2 and IP3
9 site to be approximately 0.22 person-sievert (Sv) (22 person-rem) per year for IP2, and 0.24 Sv
10 (24 person-rem) per year for IP3. The breakdown of the total population dose by containment
11 failure mode is summarized in Table 5-4. SGTR events and late containment failures, caused
12 by gradual overpressurization by steam and noncondensable gases, dominate the population
13 dose risk for both units.

14 The NRC staff has reviewed Entergy's data and evaluation methods and concludes that the
15 quality of the risk analyses is adequate to support an assessment of the risk reduction potential
16 for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs

1 and offsite doses reported by Entergy.

2 **Table 5-4. Breakdown of Population Dose by Containment Failure Mode**

Containment Failure Mode	IP2		IP3	
	Population Dose (Person-Rem ¹ Per Year)	% Contribution	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Intact Containment	<0.1	<1	<0.1	<1
Basemat Melt-through	1.1	5	0.6	3
Gradual Overpressure	7.4	34	4.4	18
Late Hydrogen Burns	0.9	4	0.6	2
Early Hydrogen Burns	2.1	10	0.8	3
In-Vessel Steam Explosion	0.1	1	0.1	0
Reactor Vessel Rupture	1.0	5	0.4	2
Interfacing System LOCA	1.6	7	1.1	4
SGTR	7.7	35	16.6	68
Total	22.0	100	24.3	100

¹One person-rem = 0.01 person-sievert

3 **5.2.3 Potential Plant Improvements**

4 Once the dominant contributors to plant risk were identified, Entergy searched for ways to
 5 reduce that risk. In identifying and evaluating potential SAMAs, Entergy considered insights
 6 from the plant-specific PSA and SAMA analyses performed for other operating plants that have
 7 submitted license renewal applications. Entergy identified 231 and 237 potential risk-reducing
 8 improvements (SAMAs) to plant components, systems, procedures, and training for IP2 and
 9 IP3, respectively.

10 For IP2, Entergy removed all but 68 of the SAMAs from further consideration because they are
 11 not applicable to IP2 as a result of design differences, have already been implemented at IP2,
 12 or are similar in nature and could be combined with another SAMA candidate. For IP3, all but
 13 62 of the SAMAs were removed from further consideration based on similar criteria. A detailed
 14 cost-benefit analysis was performed for each of the remaining SAMAs.

15 The staff concludes that Entergy used a systematic and comprehensive process for identifying
 16 potential plant improvements for IP2 and IP3, and that the set of potential plant improvements
 17 identified by Entergy is reasonably comprehensive and, therefore, acceptable.

1 **5.2.4 Evaluation of Risk Reduction and Costs of Improvements**

2 Entergy evaluated the risk-reduction potential of the remaining candidate SAMAs that were
3 applicable to each unit (68 for IP2 and 62 for IP3). The SAMA evaluations were performed
4 using realistic assumptions with some conservatism.

5 Entergy estimated the costs of implementing the candidate SAMAs through the application of
6 engineering judgment and the use of other licensees' estimates for similar improvements. The
7 cost estimates conservatively did not include the cost of replacement power during extended
8 outages required to implement the modifications, nor did they account for inflation.

9 The staff reviewed Entergy's basis for calculating the risk reduction for the various plant
10 improvements and concludes that the rationale and assumptions for estimating risk reduction
11 are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what
12 would actually be realized). Accordingly, the staff based its estimates of averted risk for the
13 various SAMAs on Entergy's risk reduction estimates.

14 The staff reviewed the basis for the applicant's cost estimates. For certain improvements, the
15 staff also compared the cost estimates to estimates developed elsewhere for similar
16 improvements, including estimates developed as part of other licensees' analyses of SAMAs for
17 operating reactors and advanced light-water reactors. The staff found the cost estimates to be
18 reasonable and generally consistent with estimates provided in support of other plants'
19 analyses.

20 The staff concludes that the risk reduction and the cost estimates provided by Entergy are
21 sufficient and appropriate for use in the SAMA evaluation.

22 **5.2.5 Cost-Benefit Comparison**

23 The cost-benefit analysis performed by Entergy was based primarily on NUREG/BR-0184,
24 "Regulatory Analysis Technical Evaluation Handbook" (NRC 1997) and was executed
25 consistent with this guidance. NUREG/BR-0058, "Regulatory Analysis Guidelines of the U.S.
26 Nuclear Regulatory Commission" (NRC 2004), has recently been revised to reflect the agency's
27 revised policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of
28 estimates should be developed—one at 3 percent and one at 7 percent (NRC 2004). Entergy
29 provided both sets of estimates (Entergy 2007b).

30 As described in Section G.6.1, Entergy identified 10 potentially cost-beneficial SAMAs (5 for IP2
31 and 5 for IP3) in the baseline analysis (using a 7-percent discount rate) and sensitivity analysis
32 (using a 3-percent discount rate) contained in the ER. Based on consideration of analysis
33 uncertainties, Entergy identified two additional potentially cost-beneficial SAMAs for IP2 in the
34 ER (IP2 SAMAs 44 and 56).

1 In response to an NRC staff request, Entergy provided the results of a revised uncertainty
 2 analysis in which the impact of lost tourism and business was accounted for in the baseline
 3 analysis (rather than as a separate sensitivity case) (Entergy 2008a). The revised uncertainty
 4 analysis resulted in the identification of two additional potentially cost-beneficial SAMAs for IP2
 5 (IP2 SAMAs 9 and 53) and one additional potentially cost-beneficial SAMA for IP3 (IP3 SAMA
 6 53).

7 The potentially cost-beneficial SAMAs for IP2 include the following:

- 8 • SAMA 9—Create a reactor cavity flooding system to reduce the impact of core-concrete
 9 interaction from molten core debris following core damage and vessel failure (cost
 10 beneficial in revised analysis, with uncertainties).
- 11 • SAMA 28—Provide a portable diesel-driven battery charger to improve direct current
 12 (dc) power reliability. Safety-related disconnect would be used to change a selected
 13 battery. This modification would enhance the long-term operation of the turbine-driven
 14 auxiliary feed water (AFW) pump on battery depletion.
- 15 • SAMA 44—Use fire water as backup for steam generator inventory to increase the
 16 availability of steam generator water supply to ensure adequate inventory for the
 17 operation of the turbine-driven AFW pump during SBO events (cost beneficial with
 18 uncertainties).
- 19 • SAMA 53—Keep both pressurizer power-operated relief valve block valves open. This
 20 modification would reduce the CDF contribution from loss of secondary heat sink by
 21 improving the availability of feed and bleed (cost beneficial in revised analysis, with
 22 uncertainties).
- 23 • SAMA 54—Install a flood alarm in the 480-volt (V) alternating current (ac) switchgear
 24 room to mitigate the occurrence of internal floods inside the 480-V ac switchgear room.
- 25 • SAMA 56—Keep residual heat removal (RHR) heat exchanger discharge valves, motor-
 26 operated valves 746 and 747, normally open. This procedure change would reduce the
 27 CDF contribution from transients and LOCAs (cost beneficial with uncertainties).
- 28 • SAMA 60—Provide added protection against flood propagation from stairwell 4 into the
 29 480-V ac switchgear room to reduce the CDF contribution from flood sources within
 30 stairwell 4 adjacent to the 480-V ac switchgear room.
- 31 • SAMA 61—Provide added protection against flood propagation from the deluge room
 32 into the 480-V ac switchgear room to reduce the CDF contribution from flood sources
 33 within the deluge room adjacent to the 480-V ac switchgear room.
- 34 • SAMA 65—Upgrade the alternate safe shutdown system to allow timely restoration of
 35 reactor coolant pump seal injection and cooling from events that cause loss of power
 36 from the 480-V ac vital buses.

37 The potentially cost-beneficial SAMAs for IP3 include the following:

Environmental Impacts of Postulated Accidents

- 1 • SAMA 30—Provide a portable diesel-driven battery charger to improve dc power
2 reliability. Safety-related disconnect would be used to change a selected battery. This
3 modification would enhance the long-term operation of the turbine-driven AFW pump on
4 battery depletion.
- 5 • SAMA 52—Proceduralize opening the city water supply valve for alternative AFW
6 system pump suction to enhance the availability of AFW system.
- 7 • SAMA 53—Install an excess flow valve to reduce the risk associated with hydrogen
8 explosions inside the turbine building or primary auxiliary building (cost beneficial in
9 revised analysis, with uncertainties).
- 10 • SAMA 55—Provide the capability of powering one safety injection pump or RHR pump
11 using the Appendix R diesel (MCC 312A) to enhance reactor cooling system injection
12 capability during events that cause loss of power from the 480-V ac vital buses.
- 13 • SAMA 61—Upgrade the alternate safe-shutdown system to allow timely restoration of
14 reactor coolant pump seal injection and cooling from events that cause loss of power
15 from the 480-V ac vital buses.
- 16 • SAMA 62—Install a flood alarm in the 480-V ac switchgear room to mitigate the
17 occurrence of internal floods inside the 480-V ac switchgear room.

18 In response to an NRC staff inquiry regarding estimated benefits for certain SAMAs and lower
19 cost alternatives, one additional potentially cost-beneficial SAMA was identified (applicable to
20 SGTR events in both units; unnumbered for each unit because the applicant did not initially
21 identify them), and one SAMA that was previously identified as potentially cost beneficial was
22 found to be no longer cost beneficial based on correction of an error in the ER (IP3 SAMA 30).

23 The staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed
24 above, the costs of the SAMAs evaluated would be higher than the associated benefits.

25 **5.2.6 Conclusions**

26 The staff reviewed Entergy's analysis and concluded that the methods used, and the
27 implementation of those methods, were sound. The treatment of SAMA benefits and costs
28 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable
29 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
30 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this
31 area was minimized by improvements that have been realized as a result of the IPEEE process
32 and inclusion of a multiplier to account for external events.

33 Based on its review of the SAMA analysis, the staff concurs with Entergy's identification of
34 areas in which risk can be further reduced in a cost-beneficial manner through the
35 implementation of all or a subset of potentially cost-beneficial SAMAs. Given the potential for
36 cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by
37 Entergy is warranted. However, none of the potentially cost-beneficial SAMAs relate to
38 adequately managing the effects of aging during the period of extended operation. Therefore,
39 they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

1 **5.3 References**

- 2 10 CFR Part 50. Code of Federal Regulations, Title 10, *Energy*, Part 50, “Domestic Licensing of
3 Production and Utilization Facilities.”
- 4 10 CFR Part 51. Code of Federal Regulations, Title 10, *Energy*, Part 51, “Environmental
5 Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- 6 10 CFR Part 54. Code of Federal Regulations, Title 10, *Energy*, Part 54, “Requirements for
7 Renewal of Operating Licenses for Nuclear Power Plants.”
- 8 10 CFR Part 100. Code of Federal Regulations, Title 10, *Energy*, Part 100, “Reactor Site
9 Criteria.”
- 10 Consolidated Edison (Con Ed). 1992. Letter from Stephen B. Bram to U.S. Nuclear Regulatory
11 Commission, Subject: Generic Letter 88-20, Supplement 1: Individual Plant Examination (IPE)
12 for Severe Accident Vulnerabilities—10 CFR 50.54, Indian Point Unit No. 2, August 12, 1992.
- 13 Consolidated Edison (Con Ed). 1995. Letter from Stephen E. Quinn to U.S. Nuclear Regulatory
14 Commission, Subject: Final Response to Generic Letter 88-20, Supplement 4: Submittal of
15 Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities,
16 Indian Point Unit No. 2, December 6, 1995.
- 17 Entergy Nuclear Operations, Inc. (Entergy). 2007a. “Applicant's Environment Report,
18 Operating License Renewal Stage.” (Appendix E to Indian Point, Units 2 and 3, License
19 Renewal Application). April 23, 2007. Agencywide Documents Access and Management
20 System (ADAMS) Accession No. ML071210530.
- 21 Entergy Nuclear Operations, Inc. (Entergy). 2007b. Letter from Fred Dacimo to U.S. Nuclear
22 Regulatory Commission, Subject: Indian Point Energy Center License Renewal Application,
23 NL-07-039, April 23, 2007. ADAMS Accession No. ML071210512.
- 24 Entergy Nuclear Operations, Inc. (Entergy). 2008. Letter from Fred Dacimo to U.S. Nuclear
25 Regulatory Commission, Subject: Reply to Request for Additional Information Regarding
26 License Renewal Application—Severe Accident Mitigation Alternatives Analysis, NL-08-028,
27 May 22, 2008. ADAMS Accession No. ML080420264.
- 28 Entergy Nuclear Operations, Inc. (Entergy). 2008b. Letter from Fred Dacimo to U.S. Nuclear
29 Regulatory Commission, Subject: Supplemental Reply to Request for Additional Information
30 Regarding License Renewal Application—Severe Accident Mitigation Alternatives Analysis, NL-
31 08-086, May 22, 2008. ADAMS Accession No. ML081490336.
- 32 New York Power Authority (NYPA). 1994. Letter from William A. Josiger to U.S. Nuclear
33 Regulatory Commission, Subject: Indian Point 3 Nuclear Power Plant Individual Plant
34 Examination for Internal Events, June 30, 1994.
- 35 New York Power Authority (NYPA). 1997. Letter from James Knubel to U.S. Nuclear
36 Regulatory Commission, Subject: Indian Point 3 Nuclear Power Plant Individual Plant
37 Examination of External Events (IPEEE), September 26, 1997.
- 38 Nuclear Regulatory Commission (NRC). 1996. “Generic Environmental Impact Statement for
39 License Renewal of Nuclear Power Plants.” NUREG-1437, Volumes 1 and 2, Washington, DC.

Environmental Impacts of Postulated Accidents

- 1 Nuclear Regulatory Commission (NRC). 1997. "Regulatory Analysis Technical Evaluation
2 Handbook." NUREG/BR-0184, Washington, DC.
- 3 Nuclear Regulatory Commission (NRC). 1999. "Generic Environmental Impact Statement for
4 License Renewal of Nuclear Plants, Main Report," Section 6.3, "Transportation," Table 9.1,
5 "Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
6 Report." NUREG-1437, Volume 1, Addendum 1, Washington, DC.
- 7 Nuclear Regulatory Commission (NRC). 2004. "Regulatory Analysis Guidelines of the U.S.
8 Nuclear Regulatory Commission." NUREG/BR-0058, Rev. 4, Washington, DC. ADAMS
9 Accession No. ML042820192.